



Product Service

CERTIFICATE

No. Z2 076729 0104 Rev. 01

Model(s):

SRP-xxx-6PA, (xxx=300-350, in step of 5)
 SRP-xxx-6PB, (xxx=250-290, in step of 5)
 SRP-xxx-6PA-HV, (xxx=300-350, in step of 5)
 SRP-xxx-6PB-HV, (xxx=250-290, in step of 5)
 SRP-xxx-BPA, (xxx=310-355, in step of 5)
 SRP-xxx-BPB, (xxx=255-295, in step of 5)
 SRP-xxx-BPC, (xxx=280-320, in step of 5)
 SRP-xxx-BPA-HV, (xxx=310-355, in step of 5)
 SRP-xxx-BPB-HV, (xxx=255-295, in step of 5)
 SRP-xxx-BPC-HV, (xxx=280-320, in step of 5)
 xxx stands for rated output power at STC.

Parameters:

Construction: Framed, with Junction box, Cable and Connectors.
 Safety Class: Class II
 Maximum System Voltage: 1500 V DC or 1000 V DC
 Fire Safety Class: Class C according to UL790
 Dust and Sand Test Method: LC1
 Dust/sand type: 95% SiO₂
 Dust/sand concentration: 5g/m³
 Testing Air Velocity: 20m/s
 Test Duration: 4h/each side

Tested according to:

IEC 61215-1(ed.1)
 IEC 61215-1-1(ed.1)
 IEC 61215-2(ed.1)
 IEC 61730-1(ed.2)
 IEC 61730-2(ed.2)
 PPP 59022A:2013

Production Facility(ies):

004571, 076729, 095290, 098633

TÜV SÜD
 ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT